

DMR Status: Approved by Test Reviewer:  
 NODI:  
 Major  
 01 SMRO  
 Public  
 Inspector Initials:

National Pollutant Discharge Elimination System (NPDES)  
 Discharge Monitoring Report  
 Permit Number: ME0101478  
 Discharge Number: 001C  
 Monitoring Period:  
 12/01/2011 TO 12/31/2011

Permittee Name/Address  
 Name: LEWISTON-AUBURN WWTF  
 Address: PO BOX 1928  
 LEWISTON, ME 04241  
 Facility: LEWISTON-AUBURN WWTF  
 Location: LEWISTON  
 Attn: Clayton M Richardson

Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type
	Min	Avg	Max	Min	Avg	Max			
00310 - BOD, 5-DAY (20 DEG. C) : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	1220	3762	2902			0	01/01	24
	Permit Reqmt.	3553 MO AVG	5329 WKLY AVG	REPORT DAILY MAX	LBS/DY			Five per Week	COMP24
		*****	*****	*****	*****	*****	MG/L		
00400 - PH : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****			0	01/01	GR
	Permit Reqmt.	*****	*****	*****	*****	9.0 MAXIMUM		Daily	GRAB
		*****	*****	*****	*****	*****	SU		
00530 - SOLIDS, TOTAL SUSPENDED : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	1528	6786	4976			2	01/01	24
	Permit Reqmt.	3553 MO AVG	5329 WKLY AVG	REPORT DAILY MAX	LBS/DY			Five per Week	COMP24
		*****	*****	*****	*****	*****	MG/L		
00545 - SOLIDS, SETTLEABLE : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****			0	01/01	GR
	Permit Reqmt.	*****	*****	*****	*****	0.3 DAILY MAX		Daily	GRAB
		*****	*****	*****	*****	*****	ML/L		
01042 - COPPER, TOTAL (AS CU) : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	N9					
	Permit Reqmt.	*****	*****	3.6 DAILY MAX	LBS/DY			Semi-Annual	COMP24
		*****	*****	*****	*****	*****	UG/L		
50050 - FLOW, IN CONDUIT OR THRU TREATMENT PLANT : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	13.1	24.2			0	99/99	RC
	Permit Reqmt.	*****	REPORT MO AVG	REPORT DAILY MAX	MGD			Continuous	RCORDR
		*****	*****	*****	*****	*****	*****		
50060 - CHLORINE, TOTAL RESIDUAL : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****					
	Permit Reqmt.	*****	*****	*****	*****	0.24 DAILY MAX		Two per Day	GRAB
		*****	*****	*****	*****	*****	MG/L		
51477 - ANALYTIC CHEMISTRY : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	0			0	01/2Y	24
	Permit Reqmt.	*****	*****	REPORT VALUE	Y=1 N=0			Once every 2 years	COMP24
		*****	*****	*****	*****	*****	*****		
Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type
	Min	Avg	Max	Min	Avg	Max	Units		

