

Permittee Name/Address

Name: LEWISTON-AUBURN WWTF  
 Address: PO BOX 1928  
 LEWISTON, ME 04241

Facility: LEWISTON-AUBURN WWTF  
 Location: LEWISTON  
 Attn: Clayton M Richardson

National Pollutant Discharge Elimination System (NPDES)  
 Discharge Monitoring Report

Permit Number: ME0101478  
 Discharge Number: 001C

Monitoring Period:  
 10/01/2011 TO 10/31/2011

DMR Status: Approved by DMR Signatory  
 NODI:

Major  
 01 SMRO

Public  
 Inspector Initials:

Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type	
	Min	Avg	Max	Min	Avg	Max				Units
TDA3B - NOAEL STAT 48HR ACU CERIODAPHRINA : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	.....	N9	.....	.....	PERCENT	Once every 2 years	COMP24	
	Permit Requirement	.....	.....	REPORT DAILY MIN	.....	.....				
TDA6F - NOAEL STAT 48HR ACU SALVELL SALMONID : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	.....	N9	.....	.....	PERCENT	Once every 2 years	COMP24	
	Permit Requirement	.....	.....	REPORT DAILY MIN	.....	.....				
00310 - BOD, 5-DAY (20 DEG. C) : J - EFFLUENT GROSS VALUE	Sample Mismatch	1545	2212	13	16	21	MG/L	0	01/01	24
	Permit Requirement	3553 MO AVG	5329 WKEY AVG	30 MO AVG	45 WKEY AVG	50 DAILY MAX		Five per Week	COMP24	
00400 - PH : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	.....	6.8	.....	7.4	SU	0	01/01	GR
	Permit Requirement	.....	.....	6.0 MINIMUM	.....	9.0 MAXIMUM		Daily	GRAB	
00530 - SOLIDS, TOTAL SUSPENDED : J - EFFLUENT GROSS VALUE	Sample Mismatch	1403	2340	12	18	25	MG/L	0	01/01	24
	Permit Requirement	3553 MO AVG	5329 WKEY AVG	30 MO AVG	45 WKEY AVG	50 DAILY MAX		Five per Week	COMP24	
00545 - SOLIDS, SETTLEABLE : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	.....	.....	.....	<0.1	ML/L	0	01/01	GR
	Permit Requirement	.....	.....	.....	.....	0.5 DAILY MAX		Daily	GRAB	
01042 - COPPER, TOTAL (AS CU) : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	9	.....	.....	13	UG/L	0	02/YR	24
	Permit Requirement	.....	9.6 DAILY MAX	.....	.....	30.3 DAILY MAX		Semi Annual	COMP24	
50050 - FLOW, IN CONDUIT OR THRU TREATMENT PLANT : J - EFFLUENT GROSS VALUE	Sample Mismatch	.....	13.7	29.5	.....	.....	.....	0	99/99	RC
	Permit Requirement	.....	REPORT MO AVG	REPORT DAILY MAX	.....	.....		Continuous	RCORDR	
Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type	
	Min	Avg	Max	Min	Avg	Max	Units			

