

Permittee Name/Address  
 Name: LEWISTON-AUBURN WWTF  
 Address: PO BOX 1928  
 LEWISTON, ME 04241

Facility: LEWISTON-AUBURN WWTF  
 Location: LEWISTON  
 Attn: Clayton M Richardson

National Pollutant Discharge Elimination System (NPDES)  
 Discharge Monitoring Report

DMR Status: Approved by DMR Signatory  
 NODI:  
 Major  
 01 SMRO  
 Public  
 Inspector Initials:

Permit Number: ME0101478  
 Discharge Number: 001C

Monitoring Period:  
 9/01/2011 TO 9/30/2011

Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type		
	Min	Avg	Max	Units	Min	Avg				Max	Units
00310 - BOD, 5-DAY (20 DEG. C) : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	2537	3470	5561		26	33	70	1	01/01	24
	Permit Reqmt.	3553 MO AVG	5329 WKLY AVG	REPORT DAILY MAX	LBS/DY	30 MO AVG	45 WKLY AVG	50 DAILY MAX		Five per Week	COMP24
00400 - PH : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****	*****	6.6	*****	7.3	0	01/01	GR
	Permit Reqmt.	*****	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM		Daily	GRAB
00530 - SOLIDS, TOTAL SUSPENDED : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	2606	4288	6731		26	36	48	0	01/01	24
	Permit Reqmt.	3553 MO AVG	5329 WKLY AVG	REPORT DAILY MAX	LBS/DY	30 MO AVG	45 WKLY AVG	50 DAILY MAX		Five per Week	COMP24
00545 - SOLIDS, SETTLEABLE : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****	*****	*****	*****	0.1	0	01/01	GR
	Permit Reqmt.	*****	*****	*****	*****	*****	*****	0.3 DAILY MAX		Daily	GRAB
01042 - COPPER, TOTAL (AS CU) : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****	LBS/DY	*****	*****	N9			
	Permit Reqmt.	*****	*****	3.6 DAILY MAX		*****	*****	30.3 DAILY MAX		Semi-Annual	COMP24
31633 - E. COLI, THERMOTOL, MF, M-TEC : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****	*****	*****	23	1986	2	05/07	GR
	Permit Reqmt.	*****	*****	*****	*****	*****	126 GEO MEAN	949 DAILY MAX		Five per Week	GRAB
50050 - FLOW, IN CONDUIT OR THRU TREATMENT PLANT : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	11.4	19.8	MGD	*****	*****	*****	0	99/99	RC
	Permit Reqmt.	*****	REPORT MO AVG	REPORT DAILY MAX		*****	*****	*****		Continuous	RCORDR
50060 - CHLORINE, TOTAL RESIDUAL : 1 - EFFLUENT GROSS VALUE	Sample Msmnt.	*****	*****	*****	*****	*****	0.03	0.09	0	02/01	GR
	Permit Reqmt.	*****	*****	*****	*****	*****	0.1 MO AVG	0.24 DAILY MAX		Two per Day	GRAB
Parameter	Quantity or Loading			Quality or Concentration			No. Ex	Freq. of Analysis	Sample Type		
	Min	Avg	Max	Units	Min	Avg				Max	Units

