

Lewiston-Auburn Water Pollution Control Authority															
Annual Treatment Plant Performance Summary															
2016															
Flow Data															
Month	Flow Data			Biochemical Oxygen Demand (5 day)				Total Suspended Solids				Violations, Invalids, Bypass Information			
	mon ave (total flow)	max day (Inf byp Q)	min day (sec byp Q)	mon ave	max day	min day	% removal	mon ave	max day	min day	% removal	Violations	CSO Byp	2nd Byp	
Jan	10.0	25.6	7.4	11.6	24.3	7.4	95	12.1	27.8	7.2	92	0	1	0	
	311.4	7.80	0.0												
Feb	12.7	26.7	7.3	12.2	26.3	6.1	94	15.8	38.9	7.4	89	1	3	0	
	368.2	3.0	0.0												
Mar	13.1	15.8	9.5	10.6	22.5	7.2	95	11.0	33.3	6.3	92	0	1	0	
	406.2	0.4	0.0												
Apr	10.7	16.0	7.8	12.6	18.3	7.8	95	12.4	20.2	6.3	92	0	1	0	
	320.5	0.002	0.0												
May	8.4	14.7	6.1	15.8	19.7	12.5	96	12.2	19.2	7.8	94	0	0	0	
	261.1	0.0	0.0												
June	6.9	12.7	5.5	10.3	17.6	3.7	97	8.3	18.8	3.5	97	3	2	0	
	208.2	2.3	0.0												
July	6.1	10.0	5.1	12.2	20.4	8.6	96	10.8	19.6	6.7	96	0	0	0	
	188.5	0.00	0.0												
Aug	5.6	9.6	4.0	13.1	29.9	7.7	96	10.5	24.6	5.9	97	1	2	0	
	163.9	0.39	0.0												
Sept	5.0	6.8	4.3	21.7	41.9	12.5	93	20.4	53.0	4.6	93	1	0	0	
	151.1	0.0	0.0												
Oct	6.2	15.4	3.4	19.9	98.8	6.8	93	18.4	124.0	2.4	93	2	1	0	
	192.7	4.5	0.0												
Nov	7.5	14.7	5.7	15.8	62.3	7.9	93	9.4	58.0	3.2	96	2	2	0	
	226.3	0.34	0.0												
Dec	7.4	18.1	5.2	12.1	26.0	7.5	94	6.2	12.0	3.2	96	0	0	0	
	229.2	0.0	0.0												
Averages	8.3	15.5	5.9	14.0	34.0	8.0	94.8	12.3	37.5	5.4	93.9				
Totals	3027.3	18.7	0.0									10	13	0	

Notes: flow units are million gallons per day total volumes are million gallons. BOD and TSS units are mg/L CSO shows the number of bypass events when a portion of the influnt flow was diverted directly to the androscoggin via Str B.