

Lewiston-Auburn Water Pollution Control Authority															
Annual Treatment Plant Performance Summary															
2021															
Month	Flow Data			Biochemical Oxygen Demand (5 day)				Total Suspended Solids				Violations, Invalids, Bypass Information			
	mon ave (total flow)	max day (Inf byp Q)	min day (sec byp Q)	mon ave	max day	min day	% removal	mon ave	max day	min day	% removal	Violations	CSO Byp	2nd Byp	
Jan	9.7	23.8	6.7	16.0	22.5	10.8	91	16.3	30.0	8.5	91	1	1	1	
	300.7	2.3	1.4												
Feb	7.0	9.3	6.1	17.5	27.9	8.2	91	15.7	24.0	5.5	91	0	0	0	
	197.1	0.0	0.00												
Mar	10.3	20.9	6.9	16.7	20.8	13.2	89	12.7	20.0	5.0	92	0	2	1	
	320.5	1.15	0.6												
Apr	10.4	22.2	8.0	10.8	20.4	7.3	94	8.4	16.5	4.0	96	2	2	1	
	312.0	0.4	0.1												
May	8.5	13.9	6.1	14.9	26.2	9.0	93	10.7	23.0	5.6	95	1	0	0	
	262.3	0.0	0.0												
June	6.1	7.0	5.4	13.5	17.3	8.4	96	10.2	18.0	4.4	97	0	0	0	
	182.9	0.0	0.0												
July	9.4	22.0	5.3	11.2	25.1	7.6	95	9.3	18.9	3.6	97	0	6	2	
	290.6	5.50	1.2												
Aug	7.0	8.7	5.9	10.8	30.7	6.2	96	7.8	21.0	3.2	98	0	0	0	
	216.6	0.00	0.0												
Sept	7.1	12.3	5.8	6.8	13.8	2.9	98	7.1	16.4	2.6	98	0	0	0	
	212.9	0.00	0.0												
Oct	7.4	23.2	5.6	12.7	18.5	8.4	96	9.5	13.0	4.0	98	0	2	2	
	230.7	4.6	0.8												
Nov	9.4	18.7	6.4	12.4	17.2	6.5	94	11.2	27.2	4.4	95	0	1	0	
	281.3	0.96	0.0												
Dec	8.7	12.1	7.2	11.6	16.5	7.3	96	8.2	18.0	4.0	97	1	0	0	
	269.2	0.0	0.00												
Averages	8.4	16.2	6.3	12.9	21.4	8.0	94.1	10.6	20.5	4.6	95.4				
Totals	3076.8	14.9	4.1									5	14	7	
2020 Averages	9.1	19.5	6.3	12.0	24.6	6.8	93.0	9.9	25.4	4.6	94.7				
Totals	3350.4	30.5	0.9									13	24	2	